

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

NO. 1425

DATE:- 01/04/26

It is certified that an inspection team headed by DMO G.B Nagar from CMO Office inspected the JEWAR PUBLIC SCHOOL, JEWAR, Gautam Buddha Nagar, on 01-04-2026 and on the basis of Water Test Report (Attached) Report No- TCI157382600004677F date- 25-03-2026, Office Of The Chief Medical Officer, G.B. Nagar. Certified that the JEWAR PUBLIC SCHOOL, has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T.Govt.

This certificate is valid for One Year.

Signature with Seal:

Name : Dr Narendra Kumar

Designation : Chief Medical Officer

Name & Address of the Office/Department :

CMO Office Sector-39 G.B. Nagar.

Signature
DMO

To

The Principal

JEWAR PUBLIC SCHOOL

JEWAR

Gautam Budh Nagar

PRINCIPAL
Jewar Public School
Jewar (G.B. Nagar)

MANAGER
Jewar Public School
Jewar, G.B. Nagar



DTCPL/GEN/01/017

DEEPA TESTING & CONSULTANT PVT. LTD.

TEST REPORT

Laboratory : Plot No. 148A, Leelawati Enclave, Tigran Road (Badli), Mayapuri, Ballabgarh, Faridabad (Hr.)-121004

Tel. Fax: 0129-2300753, (M) 9900137739, 9958235476, 9971178062

E-mail: detlrvs@gmail.com, info@detl.in, Website: www.detl.in

ULR No. TC1573526000046771

Page 01 of 01

DTCPL/25-26/772

Issue Date: 25-03-2026

Issue To : M/s JEWAR PUBLIC SCHOOL

Jewar

G.B Nagar (U.P.)-203135, India

Sample ID :

Date of sample receipt: 21-03-2026

Sample drawn by: DTCPL

Job Order No.: 4693A

Reference No.: Jps/01

Sample Description:

Drinking water from drinking str., record at office

TEST RESULTS

PERIOD OF ANALYSIS

21-03-2026 to 25-03-2026

Reference IS:10500: 2012

TESTING PROTOCOL

Sampling protocol: APHA 24th Edi.1060B

Sample Drawn by: Mr. Praveen

Sample Quantity: 2.0 Ltr. +0.5Ltr Sterilized bottle

PARAMETERS	TEST METHOD	RESULTS	UNITS	LIMITS (MAX.)	
				Acceptable	Permissible
pH value (at 25 °C)	IS: 3025 : Pt-11	6.77	---	6.5 to 8.5	
Total hardness (as CaCO ₃)	IS: 3025 : Pt-21	42.0	mg/l	200	600
Iron (as Fe)	IS: 3025 : Pt-53	BDL, <0.05	mg/l	0.3	No relaxation
Chloride (as Cl)	IS: 3025 : Pt-32	18.0	mg/l	250	1000
Total Dissolved solids	IS: 3025 : Pt-16	130.0	mg/l	500	2000
Calcium (as Ca)	IS: 3025 : Pt-40	3.8	mg/l	75	200
Magnesium (as Mg)	IS: 3025 : Pt-46	3.2	mg/l	30	100
Sulphate (as SO ₄)	IS: 3025 : Pt-24	5.6	mg/l	200	400
Temperature	IS: 3025 : Pt-9	25.0	mg/l	-	-
Zinc (as Zn)	APHA 24 th Edi. 3111B	BDL, <0.05	mg/l	5	15
Colour	IS: 3025 : Pt-4	BDL, <5.0	Hazen	5	15
Odour	IS: 3025 : Pt-5	Agreeable	---	Agreeable	Agreeable
Residual Free chlorine	IS: 3025 : Pt-26	BDL, <0.1	mg/l	0.2 (Min)(when chlorinated)	
Turbidity	IS: 3025 : Pt-10	BDL, <1.0	NTU	1	5
T. Alkalinity (as CaCO ₃)	IS: 3025 : Pt-23	28.0	mg/l	200	600
Conductivity (at 25 °C)	IS: 3025 : Pt-14	198.3	µmhos/cm	-	-
Pb Compounds (as Pb(OH) ₂)	IS: 3025 : Pt-43	ND	mg/l	0.001	0.002
Chromium (as Cr ₆₊)	IS: 3025 : Pt-52	ND	mg/l	0.05	No relaxation
Fluoride (as F)	IS: 3025 : Pt-60	ND	mg/l	1.0	1.5
Nitrate (as NO ₃)	IS: 3025 : Pt-34	BDL, <1.0	mg/l	45	No relaxation
Cyanide (as CN)	IS: 3025 : Pt-27	ND	mg/l	0.05	No relaxation

*BDL means below detectable limit

*Sample Does Conform to as per IS 10500 w.r.t. above test results

PRINCIPAL
Jewar Public School
Jewar (G.B. Nagar)

Deepa
(Sr. Chemist)

Analyst

MANAGER
Jewar Public School
Jewar, G.B. Nagar

AUTHORISED SIGNATORY

REMARKS:

- Note:
1. Sample will be retained only for One Week.
 2. The result listed refer only to the sample and applicable parameters endorsement of product is neither inferred nor implied
 3. The result given above are related to the tested sample, As received and mentioned parameters. The customer asked for the above tests only
 4. Total liability of works is limited to invoiced amount.
 5. This report cannot be used as evidence in a court of law without written approval of the lab.
 6. Certificate shall not be reproduced except in full, without the written approval of the lab.



DTCPL/GEI/01/017

DEEPA TESTING & CONSULTANT PVT. LTD.

TEST REPORT

Laboratory: Plot No. 148A, Leelawati Enclave, Tigaon Road (Hadrola), Mulheri, Ballabgarh, Faridabad (Hr.)-121004

Tel. Fax: 0129-2300753, (M): 8800137739, 9950235476, 9971178062

E-mail: dell.rsv@gmail.com, info@dell.in, Website: www.dell.in

R No. DTCPL26002696A

Page 01 of 01
DTCPL/25-26/687

Issue Date: 25-03-2026

Issue To: M/s JEWAR PUBLIC SCHOOL

Jewar

G.B Nagar (U.P.)-203135, India

Sample ID:

Date of sample receipt: 21-03-2026

Sample drawn by: DTCPL

Job Order No.: 2712b

Reference No.: Jps/01

Sample Description: Drinking water from drinking stn., record at office

TEST RESULTS

PERIOD OF ANALYSIS

21-03-2026 to 25-03-2026

Reference IS:10500: 2012

TESTING PROTOCOL

Sampling protocol: APHA 24th Edi. 1060B

Sample Drawn by: Mr. Praveen

Sample Quantity: 2.0 Ltr. + 0.5Ltr Sterilized bottle

PARAMETERS	TEST METHOD	RESULTS	UNITS	LIMITS (MAX.)	
				Desirable	Permissible
Lead (as Pb)	IS: 3025: Pt-47	ND	mg/l	0.01	No relaxation
Anionic Detergent	IS:13428-AnxK	ND	mg/l	0.2	1.0
Mineral Oil	IS: 3025 : Pt - 39	ND	mg/l	0.5	No relaxation
E-Coli	IS:1622-1981	Absent	cfu/100ml	Shall not be detectible	
Coliform Organism	IS:1622-1981	Absent	mpn/100mL	Shall not be detectible	
Taste	IS: 3025 : Pt-7	Agreeable	---	Agreeable	

*BDL means below detectable limit *ND means Not detectable

* Sample Does Conforms to as per IS: 10500 w.r.t. above test results.

- end of report -

PRINCIPAL
Jewar Public School
Jewar (G.B Nagar)

Deepa
(Sr. Chemist)

Analyst

MANAGER
Jewar Public School
Jewar, G.B. Nagar



AUTHORISED SIGNATORY

REMARKS:

- Note:
1. Sample will be retained only for One Week.
 2. The result listed refer only to the sample and applicable parameters endorsement of product is neither inferred nor implied.
 3. The result given above are related to the tested sample, As received and mentioned parameters. The customer asked for the above tests only
 4. Total liability of works is limited to invoiced amount.
 5. This report cannot be used as evidence in a court of law without written approval of the lab.
 6. Certificate shall not be reproduced except in full, without the written approval of the lab.